

RESOLUTION NO. 1018

BY THE CITY OF OSAWATOMIE, KANSAS

**A RESOLUTION AUTHORIZING THE REPAIR OF SECONDARY FLOCCULATOR PADDLE
AT THE OSAWATOMIE WATER TREATMENT FACILITY**

WHEREAS, the City of Osawatomie, Kansas, owns and operates a water treatment facility; and

WHEREAS, the flocculation basin is supposed to have two (2) flocculator paddles but has only had one functioning paddle for approximately 5 years; and

WHEREAS, redundancy at the water treatment facility is critical in order to ensure we are able to continuously produce potable water; and

WHEREAS, the city requested proposals for the repair of the flocculator paddle from Douglas Pump, JCI, and CAS Constructors, LLC approximately 10 weeks ago; and

WHEREAS, the city only received one bid for this work from CAS Constructors, LLC in the amount of \$20,950.

NOW, THEREFORE, BE IT RESOLVED by the Governing Body of the City of Osawatomie, Kansas, in regular meeting duly assembled this 23rd day of June, 2022, authorizes city staff to work with CAS Constructors LLC to perform the necessary work required to repair the second flocculator paddle.

PASSED AND ADOPTED by the Governing Body of the City of Osawatomie, Kansas this 23rd day of June, 2022, a majority being in favor thereof.

APPROVED AND SIGNED by the Mayor.

Nick Hampson, Mayor

(SEAL)

ATTEST:

Tammy Seamands, City Clerk